



बी.पी. कोइराला मेमोरियल क्यान्सर अस्पताल

दररेट सहितको प्रस्ताव पेश गर्ने सम्बन्धी सुचना

वेभसाइटमा प्रकाशित मिति: २०८०/०१/११

यस अस्पतालको नवनिर्मित Molecular Biology को तपसिल बोजिमको प्राविधिक विषयमा Third Party Validation गराउनुपर्ने भएकोले उक्त Validation सेवा प्रदान गर्ने कम्पनि/फर्मले योग्यता तथा आधिकारीक सम्बन्धी आवश्यक कागजात (Certificate of Validated Equipment's समेत) सलग्न गरि दररेट सहितको प्रस्ताव ३ (तिन) दिनभित्र यस अस्पतालमा सोझै वा ईमेल मार्फत directorbpkmch@gmail.com / bpkmchprocurement@gmail.com पठाउनुहुन अनुरोध छ । थप जानकारीको लागि अस्पतालमा सम्पर्क गर्न सकिने छ ।

तपसिल

SN	Description
1	The molecular lab shall be of BSL level 2 or greater . The HVAC system shall be managed to meet the following requirements: 1) Negative Pressure of minus 10-15 pa Unit in rooms (Which can be seen on magnehelic gauge) 2) Air Change Per Hour at least 15 ACH 3) HEPA Filter Particle Count: (H14, 0.3 Micron, 99.997%) 4) Required Stable Temperature: (20-25 Degree Celsius) 5) The relative Humidity shall be (50-60)% 6) The molecular lab must be as per standards of at least ISO class 7 and Garde C 7) Thirty Party Validation of parameters like: Negative Pressure, HEPA filter, temperature, pressure, humidity as per mentioned standards in technical specification :

डा. देव कुमार गौतम
कार्यकारी निर्देशक